

Client: DIXON SAND (PENRITH) PTY LTD
 PO BOX 148
 PENRITH NSW 2751

Job No: 7555/1
 Date: 30/04/2024
 Tested By: JF
 Checked By: AK

Project: MATERIAL ANALYSIS
 MATERIAL TESTING - 4610 OLD NORTHERN ROAD, MAROOTA

TEST RESULTS

| TEST PROCEDURE AS1141.11.1 (DRY SIEVING), 12 | | | |
|--|--|---|--|
| Material Description | Bricklaying SAND (Yellow) | | |
| Sieve Analysis | | | |
| Laboratory Number | 7555/1-563 | | |
| <u>Sieve Size</u> | Percentage Passing | Pre-treatment Nil - Standard Oven Drying | |
| 9.5mm | 100 | <div style="border: 1px solid black; padding: 5px; text-align: center;"> <p>AS1141.12 Materials finer than 75 microns in Aggregates (by washing) % Passing</p> <hr/> <p>12.4</p> </div> | |
| 4.75mm | 100 | | |
| 2.36mm | 96 | | |
| 1.18mm | 84 | | |
| 600 microns | 39 | | |
| 300 microns | 10 | | |
| 150 microns | 1 | | |
| 75 microns | 0.2 | | |
| Date Sampled | 20/03/2024 | | |
| Sampling Procedure | Sampled by Client - Tested as received | | |
| Sampling Location | Ex Maroota Quarry | | |

Form No: R 025 Version 05/06/13 - issued by ER



Nata Accreditation Number 2734
 Corporate Site Number 2727

Head Office:
 34 Borec Road, Penrith NSW 2750
 P O Box 880 Penrith NSW 2751
 Telephone: (02) 4722 2744 Facsimile: (02) 4722 2777

Accredited for compliance with ISO/IEC 17025.

A Kench 30/04/2024
 Approved Signatory



Prestons Laboratory:
 Unit 4, 18-20 Whyalla Place, Prestons NSW 2170
 Telephone: (02) 9607 6111 Facsimile: (02) 9607 6200